

RESOLUTION APPROVING A WORK AUTHORIZATION WITH CT CONSULTANTS, INC. FOR PALMER AVENUE TANK REHABILITATION PROJECT, SEWA

WHEREAS, Doug Starkey, Director of the Department of Environmental Services, has presented the following Work Authorization with CT Consultants, Inc., to-wit:

- Project Title:** Palmer Avenue Tank Rehabilitation
- Project Description:** Provide design and bidding services to replace the pinch and plug valve, install a new generator and implement the tank improvements recommended in the most recent inspection report
- Project Location:** Palmer Ave; Ashtabula Township
- Invoicing:** Hourly not-to-exceed fee of \$50,000 in accordance with agreement for Professional Services dated September 14, 1999 and the attached 2022 rate table
- Terms:** Invoices will be rendered for work performed in the preceding month and are due and payable within 30 days after presentation. Cancellation of this contract presupposes payment for work already completed. Balances thirty (30) days past due shall bear finance charges at the legal rates permitted.
- Acceptance:** Upon the authorized signature of both parties to this contract, they agree to the above prices, specifications and conditions as satisfactory. Payments will be made as outlined above and work can proceed.

NOW, THEREFORE, BE IT RESOLVED, By the Board of Commissioners of Ashtabula County, Ohio, that the Work Authorization with CT Consultants, Inc. is hereby approved in accordance with the copy of the Work Authorization now on file in this office.

BE IT FURTHER RESOLVED that the President of the Board, on behalf of the Board of Commissioners of Ashtabula County, is authorized to execute any and all necessary documents.

**ASHTABULA COUNTY COMMISSIONERS
CERTIFICATION PAGE**

Resolution No. 2022-530

December 13, 2022

**RESOLUTION APPROVING A WORK AUTHORIZATION WITH CT CONSULTANTS,
INC. FOR THE PALMER AVE TANK REHABILITATION PROJECT, SEWA**

Upon the motion of Kathryn L. Whittington, seconded by Casey R. Kozlowski.

VOTE:

J.P. Ducro IV

Casey R. Kozlowski

Kathryn L. Whittington

Absent

Aye

Aye

CERTIFICATE OF CLERK

IT IS HEREBY CERTIFIED that the foregoing is a true and correct transcript of a resolution acted upon and duly passed by the Board of County Commissioners of Ashtabula County, Ohio, on the date noted above.



Crystal Sturgill, Clerk of the Board
Board of County Commissioners
Ashtabula County, Ohio



Work Authorization

Since 1922

Name Ashtabula County Department of Environmental Services 25. W. Jefferson Street Jefferson, Ohio 44047	Date: November 8, 2022 Attn: Mr. Doug Starkey Telephone: (440) 576-3725 E-mail dgstarkey@ashtabulacounty.us	W.A.No. Fax: (440) 576-3781
--	--	--

Project Title – Palmer Avenue Tank Rehabilitation.

Project Description – Provide design and bidding services to replace the pinch an plug valve, install a new generator and implement the tank improvements recommended in the most recent inspection report.

Invoicing instructions – Hourly not-to-exceed fee of \$50,000 in accordance with Agreement for Professional Services dated September 14, 1999 and the attached 2022 rate table.

NO WORK SHALL PROCEED UNTIL SIGNED WORK AUTHORIZATION IS RETURNED BY THE OWNER.

TERMS:

Invoices will be rendered for work performed in the preceding month and are due and payable within thirty (30) days after presentation. Cancellation of this contract presupposes payment for work already completed. Balances thirty (30) days past due shall bear finance charges at the legal rates permitted.

ACCEPTANCE

Upon the authorized signature of both parties to this contract, they agree to the above prices, specifications and conditions as satisfactory. Payments will be made as outlined above and work can proceed.

ASHTABULA COUNTY

CT CONSULTANTS, INC.

By

Date Accepted

12-13-22

Date

12-13-22

Please sign and return one copy to our office.

R:\CO_ASHTABULA\Ashtabula Co. San Engr\Env\div\Work Authorizations\2022\Rehab Of Palmer Ave Tank.Docx

8150 Sterling Court | Mentor, Ohio 44060
phone: 440.951.9000 | fax: 440.951.7486 | www.ctconsultants.com

ASHTABULA COUNTY ENVIRONMENTAL SERVICES
STATE ROAD EQ TANK IMPROVEMENTS
ENGINEER'S ESTIMATE OPINION OF PROBABLE COST
August 30, 2022

Item	Description	QTY	Unit	Cost	Total
1	Mobilization/Demobilization	1	LS	\$ 30,000.00	\$ 30,000.00
2	Demolition	1	LS	\$ 20,000.00	\$ 20,000.00
3	Replace Ex. 14" Plug Valve	1	LS	\$ 26,000.00	\$ 26,000.00
4	Replace 6" Pinch Valve	1	LS	\$ 12,500.00	\$ 12,500.00
5	EQ Tank Restoration	1	LS	\$ 370,000.00	\$ 370,000.00
6	35 KW Generator	1	LS	\$ 50,000.00	\$ 50,000.00
7	Yard Gravel Replacement	50	CY	\$ 45.00	\$ 2,250.00
8	Replace Yard Hydrant	1	EA	\$ 8,000.00	\$ 8,000.00
8	Reset Water Line Valve Boxes	3	EA	\$ 1,000.00	\$ 3,000.00

Construction Sub-Total \$ 521,750.00

Contingency (20%) \$ 104,350.00

Construction Total \$ 626,100.00